

Northglenn Water Quality Laboratory
Water Report for Brent Stevens 4/13/15

Analyte	Month-Year Most Recently Analyzed	Location: Distribution System*/ Clearwell	Result	Unit	MCL (if any)	Secondary Std (if any)	Notes
Alkalinity	Mar-15	DS	50	mg/L			
Bromate	n/a	n/a	n/a	mg/L	0.1		Only required if system ozonates, which we don't
Calcium	Jun-09	CW	33.8	mg/L			
Chlorine, Free	Mar-15	DS	0.86	mg/L	4	at least 0.2	
Chloride	Mar-15	CW	26.3	mg/L		250	
Copper**	Aug-14	DS	0.08	mg/L	1.3 (Action Level)	1.0	
HAA5	Feb-15	DS	0.0203	mg/L	0.06		
Hardness, Calcium	Mar-15	DS	79	mg/L			
Hardness, Total	Mar-15	DS	109	mg/L			
Iron	Apr-15	CW	0.002	mg/L		0.3	
Magnesium	Jun-09	CW	6.22	mg/L			
Manganese	Apr-15	CW	0.01	mg/L		0.05	
Nitrate	Mar-15	CW	<0.5	mg/L	10		
Nitrite	Mar-15	CW	<0.1	mg/L	1		
pH	Mar-15	DS	8.21	su		6.5-8.5	
Silicate	n/a	n/a	n/a	mg/L			
Sodium	Jun-09	CW	25.1	mg/L			
Sulfate	Mar-15	CW	60.4	mg/L		250	
Total Dissolved Solids	Mar-15	DS	211	mg/L		500	
TTHM	Feb-15	DS	0.0274	mg/L	0.08		
Turbidity	Mar-15	DS	0.067	NTU	0.3 (95th Percentile)	1.0 (max)	

* Distribution System is an average
** Copper result is the 90th Percentile