

Ag Testing - Consulting

Account No. : 63317

Water Analysis Report



Invoice No. : 1301861
Date Received : 10/24/2019
Date Reported : 10/25/2019

Lab Number : 22412

Results For : 

Location :

Sample ID :

pH	7.8
Total Dissolved Solids (TDS) Est, ppm	183
Electrical Conductivity, mmho/cm	0.31
Cations / Anions, me/L	3.3 / 2.8

	ppm
Sodium, Na	10
Potassium, K	4
Calcium, Ca	38.0
Magnesium, Mg	11
Total Hardness, CaCO ₃	141
Nitrate, NO ₃ -N	3.0 (SAFE)
Sulfate, SO ₄ -S	4
Chloride, Cl	5
Carbonate, CO ₃	< 1.0
Bicarbonate, HCO ₃	132
Total Alkalinity, CaCO ₃	109
Total Phosphorus, P	0.17
Total Iron, Fe	< 0.01

"<" - Not Detected / Below Detection Limit

Reviewed By : Nick Ward

10/27/2019

Copy : 1

Page 1 of 1

Bus: 308-234-2418
Fax: 308-234-1940

web site
www.wardlab.com

4007 Cherry Ave., P.O. Box 788
Kearney, Nebraska 68848-0788