



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: HomeSpec, LLC
PO Box 601
Ridgefield, CT 06877
Sample Date: 1/5/2021 12:05 PM
Receipt Date: 1/5/2021 4:00 PM
Report Date: 1/7/2021
Sample Site: [REDACTED]

Sample ID#: [REDACTED]
Sample Type: Drinking Water
Sample Source: Wet Bar
Sampler: RP

| Parameter | Sample Result | Units | Limits | Method | MDL | Analysis Date |
|----------------------------|---------------|-------|--------------|------------|-------|---------------|
| Biological | | | | | | |
| Coliform Bacteria | absent | none | 0 | SM9223B-04 | 0 | 1/5/2021 |
| e Coli Bacteria | absent | none | 0 | SM9223B-04 | 0 | 1/5/2021 |
| Inorganic Compounds | | | | | | |
| Chlorine, residual | ND | mg/L | 4 | M4500CLG-2 | 0.05 | 1/5/2021 |
| Metals | | | | | | |
| Arsenic | ND | mg/L | 0.01 | EPA 200.5 | 0.002 | 1/7/2021 |
| Copper | 0.17 | mg/L | 1.3 | EPA 200.5 | 0.005 | 1/7/2021 |
| Iron | 0.10 | mg/L | 0.3 | EPA 200.5 | 0.005 | 1/7/2021 |
| Manganese | 0.006 | mg/L | 0.05 | EPA 200.5 | 0.005 | 1/7/2021 |
| Minerals | | | | | | |
| Chloride | 92.2 | mg/L | 250 | EPA 300.0 | 1 | 1/6/2021 |
| Hardness | 123 | mg/L | No Limit Set | EPA 200.5 | 5 | 1/7/2021 |
| Sodium | 27.8 | mg/L | 100 | EPA 200.5 | 1 | 1/7/2021 |
| Sulfate | 31.1 | mg/L | 250 | EPA 300.0 | 2 | 1/6/2021 |
| Nutrient | | | | | | |
| Nitrate as N | 3.0 | mg/L | 10 | EPA 300.0 | 0.5 | 1/6/2021 |
| Nitrite as N | ND | mg/L | 1 | EPA 300.0 | 0.1 | 1/6/2021 |
| Physical | | | | | | |
| Color | 5 | CU | 15 | SM2120B-23 | 0 | 1/6/2021 |
| Odor | 0 | TON | 2 | SM2150B-23 | 0 | 1/5/2021 |
| PH | 7.0 | pH | 6.4 - 8.5 | M4500HB-2 | 0 | 1/5/2021 |
| Turbidity | 1.2 | NTU | 5 | EPA 180.1 | 0.05 | 1/6/2021 |

Based on the bacteriological examination, according to the Federal Safe Drinking Water Act (SDWA), this water was safe for drinking purposes at the time the sample was collected.

ND = Not Detected
* = Above Specified Limit

CT Lic PH-0787

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: HomeSpec, LLC
PO Box 601
Ridgefield, CT 06877
Sample Date: 1/5/2021 12:05 PM
Receipt Date: 1/5/2021 4:00 PM
Report Date: 1/7/2021
Sample Site: [REDACTED]

Sample ID#: [REDACTED]
Sample Type: Drinking Water
Sample Source: Wet Bar
Sampler: RP

| Parameter | Sample Result | Units | Limits | Method | MDL | Analysis Date |
|-----------------------|---------------|-------|--------------|-----------|-----|---------------|
| Radiochemicals | | | | | | |
| Uranium | ND | ug/L | 30 | EPA 200.8 | 1 | 1/7/2021 |
| Water Radon(204769) | 3,053 +/-55 | pCi/L | No Limit Set | M7500Rn-2 | 0 | 1/5/2021 |

Comments: Based on the bacteriological examination, according to the Federal Safe Drinking Water Act (SDWA), this water was safe for drinking purposes at the time the sample was collected.

ND = Not Detected
* = Above Specified Limit

Report Approved by: _____

Lab Director

CT Lic PH-0787

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.